

DEQ MICHIGAN DEPARTMENT OF ENVIRONMENTAL QUALITY
DRINKING WATER AND RADIOLOGICAL PROTECTION DIVISION

PUBLIC SWIMMING POOL INSPECTION REPORT SUPPLEMENT

Issued under authority of Part 125 of Act 308, P.A. 1978, as amended

SP 73 - 3610 - 1

Pool Establishment Name: Saginaw High School
Address: 3100 Webber St. Saginaw city

Unless otherwise specified, the violations explained below will need to be corrected by the next routine inspection:

Item or Rule No.	Remarks	Correct By
R.325.2165	Rule 65 - New pool rules, effective Feb 16, 2001 - Re-stock safety equipment (1st Aid kit, blood spill kit, megaphone, whistle, resuscitation mask, etc.) with all required items listed on page 19 of the new Swimming Pool Rules.	
R.325.2198	Rule 98 - Signs posted at the school pool say 'When no lifeguard is on duty swim at your own risk'. Rule 98 (1)(a) says that a pool shall provide lifeguard service, if a pool is owned or operated by a school. Rule 98 (b) A swimming pool owner or operator shall post valid and current evidence of successful completion of adult, child and infant CPR and lifeguard course (by the lifeguard) - in the swimming pool enclosure.	
R.325.2176	Rule 76 - Docks locker room ceiling in poor condition. - Repair.	

Melvin C. Bagshaw
Person Interviewed

Kristina Miller
MDEQ or LHD Representative

3/27/01
Date

DISTRIBUTION: WHITE - Owner CANARY - Local Health Department PINK - MDEQ EQP 1735-1 (2/98)



Water Safety Division
P.O. Box 1045
Ann Arbor, Michigan 48106
Phone: +1-734-996-8888
FAX: +1-734-663-8888

Fatal Drowning Investigation
Location: Saginaw, Michigan
Saginaw High School
Investigator: Ken Ascher

Information requested and released through the Michigan Freedom of Information Act, Public Act Number 442 of 1976 as amended.
© 2001 Communications Electronics Inc.